

## **Recently Completed Projects**

1. 1212 Yarrow St (Willowcroft) – Sinkhole had formed behind the catchbasin. The area was explored, and the issue was resolved. The sidewalk was repoured, and seed/straw was spread.









2. 4208 Gold Crest Drive (Golden Acres) – The ditch line in front of this property needed to be regraded and the galvanized steel driveway pipe was replaced with a reinforced concrete pipe.









